



**Office of the Superintending Engineer Electric Purchase Circle-I,**  
**Electric Central Stores Complex Rail Head, Jammu.**

email no seepec1jammu@gmail.com

Tel. fax: 0191-2473402


No: SE/EPC-I/TS/ 255

Dated: 10.04.2018

**CORRIGENDUM of c-NIT No.SE/EPC-I/11/2017-18**

Sir,

Kindly read minimum creepage distance at S. No 17 in GTP as "580 mm for normal and moderately polluted atmosphere" instead of "580 mm for normal and moderately polluted atmosphere and 840 mm for heavily polluted atmosphere."

  
Superintending Engineer,  
Electric Purchase Circle-I,  
Jammu